

P.O.Box 130571  
20105 Hamburg/Germany

Tel. +49 40 33441944  
Fax +49 40 33441945

www.lohrmann.com  
info@lohrmann.com

<b>For Sale:</b>	<b>Pre-owned 810 MW Combined Cycle Gas Turbine Plant</b>
<b>Ref.-No:</b>	<b>GT-CC-055</b>

### Plant Configuration

Plant Type	Combined cycle, 2-2-1 arrangement
Plant Output	810 MW at nominal conditions
Fuel Type	Natural gas
Plant Efficiency el.	50%
YoM	2004
Operating Hrs:	68,000 LTSA OEM maintenance

### Gas Turbines

Technology	Siemens V94.3A 2 (SGT5-4000F) Hybrid Ring Combuster Rated capacity 265 MW gross Rated speed: 3,000rpm Average emissions (fired on natural gas) Nox 33.1g/GJ, OO 1.97g/GJ
------------	---

### Gas Turbine Generators

Technology	Siemens TLRI 115/52-30 Rated output: 16.5KV Rated current: 11.057KA
Nominal capacity	2x 316 MVA

### HRSG

Technology	Standard Fasel Lentjes (SFL) 2x horizontal modular three pressure system HRSG CapacityHP: 260t/hr, IP 320 t/hr, LP 37 t/hr
------------	---

### Steam Turbine

Technology	Alstom, type DKYZZ3-2N4 1B High pressure – single flow cylinder Nominal capacityRated terminal output= 280 MW
------------	---

### Steam Turbine Generators

Technology	Alstom type 50WY23Z-109 air cooled by TEWAC coolers
Nominal capacity	Rated output = 280MW – 19 KV
Water Cooled Condenser	Vacuum condenser cooled by circulating water through titanic heat exchanger

### Other

Cooling Tower	Balke Duerr hybrid coolers, 15 cells, wooden construction
Main Transformer GT	Alstom 16.5/150 KV
Main Transformer ST	Alstom 19.0/150 KV



**Further information on request**

### Important Disclaimer

Although the statements and technical information contained herein are believed to be materially accurate as of the date hereof, no representation or warranty is given as to the accuracy of any of the information provided. This document contains confidential information intended only for the use of the addressee. If you are not the intended recipient of this information then you are hereby notified that any use, dissemination, distribution or reproduction of this message is prohibited